

UPDATE ON FER COIL KIT FOR 4MXC/4GXC



eAPB2038 | January 4, 2021

It was communicated on August 30, 2019 that FER Coil Kits would be needed to facilitate the combination of American Standard and Ameristar FER compliant, condensing furnaces with 4GXC and 4MXC evaporator coils. This remains true for 4MXC or 4GXC coils that have a serial (date) number prior to 19365*.

4MXC and 4GXC coils beginning with serial (date) number 19365* and beyond include a factory installed heat shield and DO NOT require the use of the MAY*FERCOLKITAA accessory.

If it is determined based on serial (date) number that a Kit is required, please reference the below information.

The MAY*FERCOLKITA kits come with a metal heat shield, installation instructions, and required items for install. Kits are available in each coil cabinet size and must be used when installing a 4GXC or 4MXC with one of the listed furnace families.

Note: This does not affect American Standard or Ameristar non-condensing furnaces, legacy condensing furnaces, or condensing downflow models.

KIT MODEL NUMBER	ASSOCIATED COIL SIZE
MAY <u>A</u> FERCOLKITA	4MXCA/4GXCA – 14.5" wide cabinet
MAY <u>B</u> FERCOLKITA	4MXCB/4GXCB – 17.5" wide cabinet
MAY <u>C</u> FERCOLKITA	4MXCC/4GXCC – 21.0" wide cabinet
MAY <u>D</u> FERCOLKITA	4MXCD/4GXCD – 24.5" wide cabinet

MODEL NUMBERS: FURNACE FAMILIES IMPACTED:

- S9V2-VS (Date code - 19273 & after)
- S9V2 (Date code - 19273 & after)
- S9X2 – PSB Models
- S9X1
- S9B1
- A952V
- A951X